

## **Issues with extinguishing water piping systems at XFEL**

*Tuesday, 19 September 2017 10:00 (25 minutes)*

DESY experienced issues with corroding extinguishing water piping systems recently installed for the European XFEL accelerator facility. These corruptions occurred just a couple of weeks after commissioning. Water and material samples were taken, analyses were made. Different measures to solve the issues were considered. What is the current status? How could a solution look like? What are the problems to deal with and the options to repair the piping while European XFEL is close to user operation?

### **Email**

fabian.saretzki@desy.de

### **Funding Agency**

Deutsches Elektronen-Synchrotron

**Primary author:** Mr SARETZKI, Fabian (DESY)

**Presenter:** Mr SARETZKI, Fabian (DESY)

**Track Classification:** Incident investigation and Lessons learned